


ORDER 20023283

UNPLANNED MAINT. <InternalOrderSettlem.>



BUS2007-000020023283-PRD

Order	20023283	Ord.type	PM06	
Sup. Order		Act.type	P03	
Planning grp	H80	M.Plan		
Priority	1	Item		Main WC MECHAPSM
STATUS	REL PCNF ESTC NMAT PRC SETC			
Description	BORD. STAB. Y-STRAINERS PLUGGED			

DUE DATE 02/06/2014

Func. Loc.	HZ-T0-EGF-A069254	Location
	BORDOVSKY STABILIZER	Room
	OCC/TRRC Number	
	Field Name	
	Meter ID Number	
Equipment		Cost Center A069254
		ABC ind.
	Begin Guarantee	
	Warranty End	

Sort Field
 Manufacturer :
 Manuf. Serial no:
 Model no :
 Technical ID no:
 Size/Dimension :

Operation list

Op	Sub	Description	Workcenter
		BORD. STAB. Y-STRAINERS PLUGGED	
		02/06/2014 09:35:11 Dana Parker (PARKEDB) Phone 1 281-552-6717	
		The y-strainers on P-10507, P-10508, and P-10509 were plugged. Maintenance has completed the job already.	
0010		BORD. STAB. Y-STRAINERS PLUGGED	MECHAPSM
		BORD. STAB. Y-STRAINERS PLUGGED	
		The y-strainers on P-10507, P-10508, and P-10509 were plugged. Maintenance has completed the job already.	
0020		(DITROL) LABOR	MECHAPSM
0030		(DLS) LABOR	MECHAPSM
0040		(PAC) LABOR	MECHAPSM